

CERTIFICATE OF QUALITY AND QUANTITY



Certificate No. : FB-274/2018
Issued Date : July 31'2018
Product Name : SHERA wall board 1.0x120x260cm
Product Code : BCS001004860001
Invoice Number : -
Quantity : -
Sample size : -
Batch Number : M181805051

Description	Specification	Tolerance	Unit	Test Result	Reference
Thickness	10	± 0.60	mm	Avg. 10.13	IS-01-PDM-011
Width	1200	± 2.0	mm	Avg. 1200.28	
Length	2600	± 3.0	mm	Avg. 2600	
Straightness of Edges	≤ 2.4	-	mm	Avg. 2.14	
Squareness of Edges	≤ 2.5	-	mm/m	Avg. 0.74	
Modulus of Rupture (Cross Direction)	≥ 6	-	MPa	Avg. 9.53	
Modulus of Rupture ((CD + MD)/2)	≥ 7	-	MPa	Avg. 11.74	
Toughness (Cross Direction)	≥ 3.5	-	J/m ²	Avg. 20.56	
Impact Strength (Machine Direction)	4,000 – 10,000	-	J/m ²	Avg. 6093.47	
Appearance	No defect	-	-	Passed	

Note : Sample size based on MIL-STD-105E.

The goods are free from asbestos.

The goods were made of cement, cellulose and sand.

Tested by ;  (Miss. Sakaorat Chaiyajak) Quality Engineer Date 31/7/18	Approved by ;  (Mr. Rungroj Rangyai) Quality Assurance Manager Date 31/07/18
--	---