

CERTIFICATE OF QUALITY AND QUANTITY

FB-600/2020 Certificate No.

Issued Date SEPTEMBER 23, 2020

SHERA BOARD LOFT GREY BOARD, SQUARE-CUT SIZE: 12X1220X2440 MM Product Name

BYS001214809601 Product Code

Invoice Number 2000034742 Date: 23.09.2020

Quantity 816 pcs. Sample size 5 pcs

M.A.L.M. GROUP LTD. ISRAEL Customer's name

Batch Number M172008173

Description	Specification	Tolerance	Unit	Test Result	Reference
Thickness	12	± 0.72	mm	Avg. 12.01	IS-01-PDM-011
Width	1220	± 2.0	mm	Avg. 1219.96	
Length	2440	± 3.0	mm	Avg. 2440	
Straightness of Edges	≤ 2.44		mm	Avg. 1	
Squareness of Edges	≤2.5		mm/m	Avg. 0.60	
Modulus of Rupture (Cross Direction)	≥6		MPa	Avg. 7.93	
Modulus of Rupture ((CD + MD)/2)	≥7	% 5 - :	MPa	Avg. 11.17	
Toughness (Cross Direction)	≥ 3.5	-	J/m ²	Avg. 7.18	
Toughness (Machine Direction)	≥ 10	-	J/m ²	Avg. 37.35	
Impact Strength (Machine Direction)	4,000 - 10,000	-:	J/m ²	Avg. 7383	
Appearance	No defect	4 0	-	Passed	

Note: Sample size based on MIL-STD-105E.

The goods are free from asbestos.

The goods were made of cement, cellulose and sand.

Weight Average/pcs 55.890 kg

Density Range 1.30-1.40 g/cm

Tested by;

Date

(Miss. Sakaorat Chaiyajak)

Quality Engineer

Approved by;

(Mr Rungroj Rangyai)

Quality Assurance Manager

23/9/2020

Date



TEST REPORT

Certificate No. FB-600/2020

Issued Date SEPTEMBER 23, 2020

Product Name SHERA BOARD, LOFT GREY BOARD, SQUARE-CUT SIZE:

12X1220X2440 MM

Product Code BYS001214809601 Number of P/I MAE/20/0218 Date of P/I 07.09.2020

PO NO. 323

Commercial Invoice Number 2000034742 Date of Commercial Invoice 23.09.2020 Quantity 816 pcs. Sample size 5 pcs

Customer's name M.A.L.M. GROUP LTD. ISRAEL :

Batch Number M172008173

Description	Specification	Tolerance	Unit	Test Result	Reference
Thickness	12	± 0.72	mm	Avg. 12.01	IS-01-PDM-011
Width	1220	± 2.0	mm	Avg. 1219.96	
Length	2440	± 3.0	mm	Avg. 2440	
Straightness of Edges	≤ 2.44	-	mm	Avg. 1	
Squareness of Edges	≤2.5		mm/m	Avg. 0.60	
Modulus of Rupture (Cross Direction)	≥6	- T	MPa	Avg. 7.93	
Modulus of Rupture ((CD + MD)/2)	≥ 7	-	MPa	Avg. 11.17	
Toughness (Cross Direction)	≥3.5	-	J/m ²	Avg. 7.18	
Toughness (Machine Direction)	≥ 10	-	J/m ²	Avg. 37.35	
Impact Strength (Machine Direction)	4,000 - 10,000	-	J/m ²	Avg. 7383	
Appearance	No defect	-	-	Passed	

pH = 7-8

Flame Ability SHERA Board passed fire resistant standard listed as below

Standard	Result
BS 476 part 4 (Non-combustible product)	Pass
BS 476 part 5 (ignitability)	Pass
BS 476 part6 (fire propagation)	Pass
BS 476 part 7	Page

Composition

Substance Name	CAS Number	UN Number	Proportion
Crystalline Silica (Quartz)	14808-60-7	None allocated	30-40 %
Portland Cement	65997-15-1	None allocated	30-40 %
Cellulose	9004-34-6	None allocated	< 10 %
Other non hazardous ingredients			10-40 %
(£11)			

(fillers)

(IIIICIO)		
Bending Resistant	Refer to MOR	
Water tightness		PASS
Moisture (%)	≤ 15	PASS
Density (g/cm³)	1.3-1.40	PASS
Water Absorption (%)	≤ 35	PASS
Length change (%)	\leq 0.10	PASS

Note: Sample size based on MIL-STD-105E.

(Miss. Sakaorat Chaiyajak) Quality Engineer

23/9/2020

Approved by;

(Mr. Rungroj Rangyai) Quality Assurance Manager

Date

Date

Tested by;





Manufacturer's Declaration

INVOICE NO.:2000034742

L/C NO .: -

BUYER: M.A.L.M. GROUP LTD. ISRAEL

DESCRIPTION OF GOODS: SHERA BOARD, LOFT GREY BOARD, SQUARE-CUT SIZE: 12X1220X2440 MM

(BYS001214809601)

QUALITY STANDARD: AS PER TEST REPORT

WE HEREBY CONFIRM THAT THE ABOVE MENTIONED PPRODUCTS IS
IN ACCORDANCE WITH THE TEST REPORT NO: FB-600/2020.(STANDARD NO.IS01-PDM-011) AND THE PRODUCTS MEET QUALITY REQUIREMENTS AS MENTIONED
IN THE TEST REPORT AND WE HEREBY ACCEPT ALL RESPONSIBILITIES FOR ALL
LOSSES AND DAMEGES IF THE TEST RESULTS PERFORMED BY ISIRI FOUND ANY
NON CONFORMITY WITH ABOVE STANDARD QUALITY REQUIREMENTS.
THE ABOVE TEST REPORT IS ATTACHED

DATE OF ISSUE: SEPTEMBER 23, 2020

NAME OF MANUFACTURER: Shera Public Company Limited.

SIGNATURE.

(Mr. Řungroj Rangyai)

Quality Assurance Manager