

## **CERTIFICATE OF ANALYSIS**

Certificate No.	:	FB-241
Issued Date	:	May 25' 2011
Product Name	:	SHERA Flexy Board size: 0.6x122x244 cm.
		SHERA Flexy Board size: 0.8x122x244 cm.
		SHERA Flexy Board size: 1.0x122x244 cm.
		SHERA Flexy Board size: 1.2x122x244 cm.
Data Collection	:	In April 2011

Description	Specification	Tolerance	Unit	Sample size	Test Result	Reference
Impact Strength of Board 6.0 mm.	4,000 - 10,000	-	J/m <sup>2</sup>	169	Avg. 6,843.09	
Impact Strength of Board 8.0 mm.	4,000 - 10,000	-	J/m <sup>2</sup>	32	Avg. 5,568.19	IS-01-PDM-011
Impact Strength of Board 10.0 mm.	4,000 - 10,000	-	J/m <sup>2</sup>	132	Avg. 5,849.53	
Impact Strength of Board 12.0 mm.	4,000 - 10,000	-	J/m <sup>2</sup>	53	Avg. 7,318.98	

Note : Sample size based on MIL-STD-105E.

The goods are free from asbestos. The goods were made of cement, cellulose and sand.

Tested by ;	(Mr. Nitas Udomlap) Quality Engineer	Approved by ; (Mr. Peeramate Pongthongmuang) Quality Assurance Manager
Date	25-May-11	Date 25-5-11