



CERTIFICATE OF QUALITY AND QUANTITY

Certificate No. : FB-270/2024
Issued Date : OCTOBER 12, 2024
Product Name : SHERA BOARD 2.6 M, SQUARE EDGE, UNCOLORED
SIZE: 10x1200x2600MM
Product Code : BCS001004860001
Invoice Number : 2117000193 Date: 12.10.2024
Quantity : 972 pcs.
Sample size : 5 pcs.
Customer's name : M.A.L.M LTD.
Batch Number : DPL2106281 DPL2106293 DOL2106301

Description	Specification	Tolerance	Unit	Test Result	Reference
Thickness	10	± 0.60	mm	Avg. 10.36	IS-01-PDM-011
Width	1200	± 2.0	mm	Avg. 1201	
Length	2600	± 3.0	mm	Avg. 2599.2	
Straightness of Edges	≤ 2.44	-	mm	Avg. 0	
Squareness of Edges	≤ 2.5	-	mm/m	Avg. 0.41	
Modulus of Rupture (Cross Direction)	≥ 6	-	MPa	Avg. 11.95	
Modulus of Rupture ((CD + MD)/2)	≥ 7	-	MPa	Avg. 11.49	
Toughness (Cross Direction)	≥ 3.5	-	J/m ²	Avg. 11.44	
Toughness (Machine Direction)	≥ 10	-	J/m ²	Avg. 35.21	
Impact Strength (Machine Direction)	4,000 – 10,000	-	J/m ²	Avg. 6840.12	
Appearance	No defect	-	-	Passed	
Asbestos test	Negative	-	-	Negative	

Note : Sample size based on MIL-STD-105E.


The goods are free from asbestos.

The goods were made of cement, cellulose and sand.

Weight Average/pcs 48.440 kg

Density Range 1.30-1.40 g/cm


Tested by ;


(Mrs. Kanokwan Manonumethakul)
QC Report

Date

17/10/24

Approved by ;


(Mr. Kasidit Kadesakul)
QC Supervisor

Date

17/10/24